



### CERTIFICATE OF ANALYSIS

Client: Dan Mensour  
 Company: Lecoupe Arctic Glacier  
 Address: 433 McKim Street  
 Sudbury, ON, P3C 2L4  
 Phone: (705) 675-4423  
 Email: lecoup@on.aibn.com  
 Sampled By:

Work Order Number: 314879  
 PO #:  
 Regulation: ODWS  
 Project #:  
 Fax: (705) 673-8116  
 DWS #:

Date Order Received: 8/29/2017  
 Arrival Temperature: -1°C

Analysis Started: 8/30/2017  
 Analysis Completed: 9/1/2017

### TEST RESULTS

Sample Description	Lab ID	Type / Matrix	Date / Time Collected	Field Chlorine		EC	TC	HPC
				Free	Total			
Date Code # 2418	909533	Grab / Water	8/29/2017 3:00 PM			0	0	<10
Date Code # 2418	909533r	Grab / Water	8/29/2017 3:00 PM					<10

Result Units: CFU/100mL (water matrix) CFU/g (soil matrix), except HPC which is CFU/1mL. Temp. is in Degrees Celsius.

Note that all tests have been performed in accordance with our accredited and licensed test methods (Method Reference A10 for E. coli, fecal, total coliform and background, and Method Reference A68 for HPC).

This report has been approved by:

Khaled Omari, Ph.D.  
 Laboratory Director

### LEGEND

TESTS EC - Escherichia coli, TC - Total Coliforms, FC - Fecal Coliforms, Back - Background, HPC - Heterotrophic Plate Count  
 RESULTS ~ - No Data. Results Pending.  
 INT - Interferences are evident on plate and therefore bacterial colonies cannot be properly counted (interferences can be anything that inhibit the proper growth and formation of target colonies)  
 NDOGN - No Data, Overgrown with Non-Target  
 NDOGT - No Data, Overgrown with Target  
 NDOGHPC - No Data. Overgrown with HPC  
 An 'r' after the Lab ID indicates a laboratory replicate.  
 Results relate only to the items tested.